

# Certificate of Compliance

**Certificate:** 1394501

**Master Contract:** 218759

**Project:** 1394501

**Date Issued:** January 16, 2002

**Issued to:** Steeldesign GmbH  
Brüsseler Straße 6  
53842 Troisdorf  
GERMANY

*The products listed below are eligible to bear the CSA Mark shown  
with adjacent indicators 'C' and 'US'*

A handwritten signature in blue ink, appearing to read 'D. Li', is positioned above the authorized person's name.

**Authorized by:** Davey Li, P. Eng.  
Manager - Engineering

## PRODUCTS

CLASS 3211 07 - INDUSTRIAL CONTROL EQUIPMENT – Miscellaneous Apparatus

CLASS 3211 87 - INDUSTRIAL CONTROL EQUIPMENT – Miscellaneous Apparatus-  
Certified to U.S. Standards

Industrial Control Panel Enclosures, for general purpose and special purpose application, for wall mounting:  
Series

TX...; NEMA Type 4X, Type 12

EX...; NEMA Type 4X, Type 12

EXE...; NEMA Type 4X, Type 12

## General Notes

1. These are metal enclosures intended for use with industrial control equipment where the acceptability of the combination has been determined by CSA INTERNATIONAL.
2. The type designations are completed by suffixes indicating dimensions. Accessories as indicated in the Certification Report may be provided or supplied with.
3. These enclosures, where entry of supply conductors is not made by trade size conduit connections of NPT are subject to acceptance by Local Inspection Authority having jurisdiction.
4. The Certification of this submitter's enclosures covers mechanical parts only (no electrical parts are involved)

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.



**Certificate:** 1394501

**Project:** 1394501

**Master Contract:** 218759

**Date:** January 16, 2002

**APPLICABLE REQUIREMENTS**

CSA Standard C22.2 No. 0 –M91	-	General Requirements
CSA Standard C22.2 No. 0-4 – M1982	-	Bonding and Grounding of Electrical Equipment
CSA Standard C22.2 No. 14-95	-	Industrial Control Equipment
CSA Standard C22.2 No. 94-M91	-	Special Purpose Enclosures
US Standard UL 50, 11 <sup>th</sup> Edition	-	Special Purpose Enclosures

Electrical Certification Notices Nos. 587 and 587A.



## *Supplement to Certificate of Compliance*

**Certificate:** 1394501

**Master Contract:** 218759

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

<b>Project</b>	<b>Date</b>	<b>Description</b>
1394501	January 16, 2003	CCSAus initial certification of types TX...; EX...; EXE....